

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2023/SZ/534

Dated: 07/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M.H.D.C. Saraswati Bal Mandir, B-1, Janakpuri, New Delhi-110058, comprised of ground floor plus two upper floors, having total 23 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Sports Room, Hall & Store etc.) owned/occupied by Samarth Shiksha Samiti, Delhi (Regd.) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/303 dated 24/08/2020. The School building was re-inspected by the officer concerned of this department on 26/07/2023 in the presence of Smt. Ritu Sood (Principal) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 07/08/2023 at New Delhi.

  
 (Atul Garg)  
 Director  
 Delhi Fire Service

24.

Copy to:-

1. The Principal,  
M.H.D.C. Saraswati Bal Mandir,  
B-1, Janakpuri, New Delhi-110058
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

  
 Manager

  
 Principal  
**M.H.D.C. SARASWATI BAL MANDIR**  
 B-1 Block, Janakpuri, New Delhi-58

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.